



GAF Everguard TPO Concrete Substrate Readiness

Installation Support Checklist

1. Structure complies to the New Zealand Building Code and concrete complies with NZS 3101 (2006)
2. Concrete cured with curing membranes removed. Concrete substrate contains less than 5% moisture content.
3. Surface smooth and clean with falls as per plan.
4. Cavities and cracks filled, flushed off and cured.
5. Concrete surface firm with any soft concrete or laitance removed.
6. Ponding areas removed.
7. Roof drains and overflow recesses formed to fit rebated outlets.
8. If terminating into a chase, pre-form the chase, straight and 20mm deep.
9. Plinths formed for any exterior ventilation, solar panels or fixtures.
10. Construction joints incorporated in slab as per designers specification.
11. Substrate clean, firm and suitable condition for laying GAF Everguard TPO.

Project records

_____ Project Name
_____ Name
_____ Company
_____ Applicator