



# GAF Everguard TPO Roof Plywood Substrate Readiness

## Installation Support Checklist

---

1. CCA H3.2 treated (Not LOSP) plywood sheets used, 17mm thick for roofs, 21mm thick for decks.
2. Plywood sheets supported by joists and nogs at maximum 400mm centres in both directions, unless specified otherwise.
3. Sheets stagger lay (fully offset) with the face grain at right angles to the primary supports
4. All sheet edges supported by nogs, fixed 150mm on edges and 200mm through girth, edges butt-jointed with no gaps except at abutments.
5. Sheets glued in place and then fixed using 316 grade Stainless Steel 10 gauge countersunk screw fixings.
6. All decks and gutters have correct falls once installed.
7. Rainwater outlets and overflow recesses formed to fit outlets rebated into the surface.
8. 5mm clearances from all abutments, 5mm radius to all exposed edges.
9. Sharp edges and lips removed and cavities filled. All joints flush.
10. Substrate dry (20%), clean, firm and suitable condition for laying.

### ***Project records***

\_\_\_\_\_ Project Name  
\_\_\_\_\_ Name  
\_\_\_\_\_ Company  
\_\_\_\_\_ Applicator